

Certificate

**Honeywell International Inc.
Honeywell Field Solutions
512 Virginia Drive
Fort Washington, PA 19034, USA**

The safety related
STT25S Temperature Transmitter

meets the requirements listed in the following standard


IEC 61508-1:1998; IEC 61508-2:2000; IEC 61508-3:1998; Functional safety of electrical/electronic/programmable electronic safety-related systems

SIL 2 capability for single transmitter use

SIL 3 capability for multiple transmitter use

based on report no. SAS-135/2006T in the valid version.

This certificate entitles the holder to use the certification mark:




Certificate-Register-No.: SAS 1425/07, Vers. 1.0, Augsburg, 2007-Oct-16

File reference: M.IB5.03.085.05.SLA

Valid to: 2012-Oct-16

TÜV NORD SysTec GmbH & Co. KG
Branch South
Halderstr. 27
86150 Augsburg / Germany



Dr. Immanuel Höfer

07